



INVITATION TO BID NO: 2252868      ADDENDUM NO: 02

STATE OF ALABAMA  
DEPARTMENT OF FINANCE  
DIVISION OF PURCHASING

REQ. AGENCY : 012035  
ALDOT - 6TH DIVISION  
AGENCY REQ. NO. : 604-361442  
T-NUMBER :  
DATE ISSUED : 08/01/13  
VENDOR NO. :  
VENDOR PHONE NO. :  
SNAP REQ. NO. : 1511777  
BUYER NAME : RAY BRESSLER  
BUYER PHONE NO. : (334) 242-4670

INVITATION TO BID ADDENDUM

FOR: GENERATORS - 6-1 & 6-3

BID MUST BE RECEIVED BEFORE:  
DATE: 08/02/13    TIME: 5:00 PM

BIDS WILL BE PUBLICLY OPENED:  
DATE: 08/05/13    TIME: 10:00 AM

PLEASE READ ALL INSTRUCTIONS CAREFULLY

THE FOLLOWING CHANGES ARE HEREBY ADDED TO AND MADE A PART OF  
(INVITATION TO BID NUMBER 2252868 )

1. REFER TO PLUMBING NOTES ON DRAWING SHEETS E1 AND E2 AND GENERAL NOTES ON DRAWING SHEETS A1 AND A2. CLARIFICATION: CHANGE SHEET A1 GENERAL NOTE 2 AND SHEET A2 GENERAL NOTE 3 TO READ AS FOLLOWS:  
"PROVIDE FLEXIBLE CONNECTOR IN GAS PIPING PER GENERATOR MANUFACTURER'S INSTRUCTIONS. ALL FLEXIBLE CONNECTIONS TO BE BRAIDED STAINLESS STEEL DESIGNED FOR OUTDOOR USE IN NATURAL GAS PIPING."

2. REFER TO PANELBOARD SCHEDULE ON DRAWING SHEETS E1 AND E2. "ALL PANELS SHALL BE FIELD MARKED TO WARN OF POTENTIAL ELECTRIC ARC FLASH HAZARD PER NEC 110.16."

3. REFER TO DRAWING SHEET E2, RISER DIAGRAM. SEE THE ATTACHED DIAGRAM OF THE THE EXISTING OFFICE BUILDING. . INSTALL THE ANNUNCIATOR IN THE CORRIDOR ON THE WALL ADJACENT TO THE MECHANICAL ROOM AT A HEIGHT COMPLYING WITH ADAAG GUIDELINES AND IN THE LOCATION ON THE WALL AS APPROVED BY THE OWNER'S REPRESENTATIVE. THE WIRING/CONDUIT SHOULD GO OVER THE BOILER AND MECHANICAL ROOM AS MUCH AS POSSIBLE AND PENETRATE THE CORRIDOR WALL AT THE ANNUNCIATOR.

FIELD MEASURE THE DISTANCE TO RUN UNDERGROUND FROM GENERATOR BUILDING TO THE OFFICE BUILDING. CONDUITS SHALL BE RIGID GALVANIZED FOR EXTERIOR RUNS (PAINTED WITH ASPHALTUM PAINT WHERE UNDERGROUND) AND EMT FOR INTERIOR RUNS. INTERIOR CONDUIT RUNS SHALL RUN IN UTILITY SPACES AND NOT BE SEEN IN PUBLIC AREAS.

(CONTINUED)

STATEMENT OF UNDERSTANDING

I UNDERSTAND THE ADDENDUM AND THAT, IF INDICATED, IT MUST BE SIGNED IN INK AND RETURNED WITH THE BID OR SEPARATELY, PROPERLY IDENTIFIED AND RECEIVED PRIOR TO DATE AND TIME SPECIFIED.

ADDENDUM NOTARIZATION  
NOT REQUIRED

\_\_\_\_\_  
COMPANY NAME

\_\_\_\_\_  
AUTHORIZED SIGNATURE (INK)

\_\_\_\_\_  
MAIL ADDRESS

\_\_\_\_\_  
TYPE/PRINT AUTHORIZED NAME

\_\_\_\_\_  
CITY, STATE, ZIP

\_\_\_\_\_  
PHONE INCLUDING AREA CODE

VENDOR NAME :  
VENDOR NUMBER :

08/05/13

10:00 AM

2

4. REFER TO ELECTRICAL SPECIFICATIONS, SECTION 260000: IN PARAGRAPH 10.21, THE AUTOMATIC TRANSFER SWITCH SHALL BE RATED AT LEAST 22,000 AIC IN LIEU OF 65,000 AIC.

5. REFER TO SHEET E-1, PANELBOARD SCHEDULE: PANEL D1 AND INSTALLED BREAKERS SHALL BE RATED AT LEAST 22,000 AIC.

6. REFER TO SHEET E-1, RISER DIAGRAM: PROVIDE A PHENOLIC LABEL ON EXISTING SERVICE ENTRANCE DISCONNECT SWITCH STATING THE AVAILABLE FAULT CURRENT PER NEC 110.24 IS 14,865 AMPS.

7. REFER TO SHEET E-2, PANELBOARD SCHEDULE: PANEL D3 AND INSTALLED BREAKERS SHALL BE RATED AT LEAST 22,000 AIC.

8. REFER TO SHEET E-2, RISER DIAGRAM: PROVIDE A PHENOLIC LABEL ON EXISTING SERVICE ENTRANCE DISCONNECT SWITCH STATING THE AVAILABLE FAULT CURRENT PER NEC 110.24 IS 11,168 AMPS.

IN ADDITION TO ITEMS ABOVE:

THE DIVISION WISHES TO CLARIFY THE STATEMENT IN THE EXECUTION AND CLOSEOUT REQUIREMENTS SECTION. ON PAGE 9 OF THIS SECTION UNDER 3.13 MAINTENANCE, ARTICLE B, WE WANT IT UNDERSTOOD THAT A "MAINTENANCE PERIOD OF ONE (1) YEAR FROM THE DATE OF SUBSTANTIAL COMPLETION OR THE LENGTH OF THE SPECIFIED WARRANTY, WHICHEVER IS LONGER" IS WHAT IS REQUIRED. WE DO NOT WANT IT MISINTERPRETED TO BE A FIVE(5) YEAR SERVICE CONTRACT. ALSO WE WISH TO REMOVE THE FOUR(4) INCH THICK BY FOUR(4) FEET WIDE CONCRETE PAD THAT SURROUNDS THE TEN(10) INCH RAISED CONCRETE PAD THE GENERATOR WILL SIT ON AT THE DISTRICT 1 LOCATION.

BID MUST BE RETURNED BEFORE 5:00 PM 08-08-13 AND  
BID OPENS ON 08-09-13 AT 10:00 AM.

THIS ADDENDUM MUST BE RETURNED WITH ORIGINAL BID AND WITH COMPLETE EXACT COPY OF ORIGINAL BID.

\* \* \* \* \* END OF ADDENDUM \* \* \* \* \*