

Solicitation No. 10-R-2213793 Addendum

The Trane model # will be WE1 50E300A for the Air Handler and it will have a 3 horse power motor to insure proper air flow. There shall be one 12 ½ ton unit.

The condenser model # will be TTA150E400A 460 VOLT 3/PH.

If the 12 ½ ton unit is not in stock we will accept a 15 ton unit in Trane or American Standard with R-22 or 410A Freon.

A Freon Contractor will need to check for proper line size if the Freon lines now are not the right size.

Model # for the Air Flow Switch will be Honeywell Brand S688A1007 or Equal.

Contractor will replace drain pan under new air handler.

Contractor will have a city inspection.